

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0569:126

Page 1 of 1

**CATEGORY:** Audible Devices

**LISTEE:** Gentex Corporation, 10985 Chicago Dr., Zeeland MI 49464  
Contact: \*Keiffer Sestric (616) 392-7195 Fax (616) 392-4219

**DESIGN:** Model GX91 and GX93 horn. Model GX-93 has selectable continuous or temporal tones. Refer to listee's data sheet for additional product description and operational considerations.

**RATING:** Electrical: 8-33 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings and UL label.

**APPROVAL:** Listed as horns for use with separately listed compatible fire alarm control units. For indoor use only.

Unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

\*Rev. 12-09-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**DECEMBER 9, 2003**

*Listing Expires June 30, 2004*

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager